

SOE-24H

Multi-Sensor

Features

- ▶ High signal-to-noise ratio and sensitivity stability are effective in a wide range of environmental conditions
- ▶ Wide viewing angle alarm indicators
- ▶ Automatic drift compensation and maintenance indication
- ▶ Built-in magnetic test feature
- ▶ Break-away, hidden locking feature for use with NS bases
- ▶ Optimized reduction to false alarms and enhanced reaction time to real fires



Description

The SOE-24H is a UL 268 7th Edition listed Multi-Criteria Detector, featuring optical smoke detection combined with heat detection, which can be used in all open areas where either of both types of detection are required.

The new multi-spectrum smoke categorisation technology detects smoldering

and flaming fires, including those from polyurethane fuels, and at the same time can reduce false alarms from cooking fumes. The device's heat sensing element can detect temperatures up to 135°F.

Technical information

Sensing Element	Heat	Thermistor
	Smoke	IR LED, Blue LED, Photodiode
Supply Voltage	Operating Voltage Range	8-35VDC
	Absolute Max Voltage	42VDC
	Maximum Voltage Ripple	8200m VAC
	Maximum Input Capacitance	0.01uF
Current Consumption	Standby Current	59µA
	Minimum Allowable Alarm Current	5mA
	Maximum Allowable Alarm Current	150mA
Startup	Time	25s (Max)
	Current	160uA (Max)
Reset	Time	100ms (Min)
	Voltage	2.5V (Min)
Compatible Bases	NS4-100, NS6-100, NS4-220, NS6-220, NS4-221, NS6-221, NS4-224, NS6-224	
	HSC-220R, HSC-221R, HSC-224R, HSC-4R, HSC-4R12	
	*W suffix (not listed above) indicates white color	
Operating Temperature Range	32°F ~ 117°F	
UL Listed Ambient Temperature	32°F ~ 117°F	
Storage Temperature Range	-22°F ~ +140°F	
Operating Humidity Limit	<95%RH at 104°F, <85%RH at 140°F	
Dimension	3.94" diameter x 2.16" tall	
Color	Ivory	
Weight	3.53 oz.	
Air Velocity Range	0-4000 fpm	
Sensitivity Range	1.80-3.16%/ft	





For further information visit our website. Hochiki reserves the right to alter the specification of its products from time to time without notice. Although every effort has been made to ensure the accuracy of the information contained in this document it is not warranted or represented by Hochiki to be a complete and up-to-date description. Check online for current version.



Detector Spacing

Smoke sensor spacing shall be in compliance with NFPA 72. For smooth ceilings and in the absence of specific performance-based design criteria, the distance between smoke sensors shall not exceed a nominal spacing of 30 ft. (9.1m) or all points on the ceiling shall have a sensor within a distance equal to or less than 0.7 times the nominal 30 ft. (9.1m) spacing. Sensors shall be located within a distance of one-half the nominal spacing, measured at right angles from all walls or partitions extending upward to within the top 15 percent of the ceiling height. For additional instructions see NFPA 72

PRODUCT LISTINGS	
<p>SIGNALING</p>  <p>LISTED</p>	 <p>APPROVED</p>
S1383	455802

