

: F9gMdy Photometric Data

EL-DL2
Corridor Luminaire



| NON-MAINTAINED | 2m Wide Corridor | |
|---------------------|-----------------------------|-----------------------------|
| Mounting Height (m) | Spacing 1 Lux Axial to Wall | Spacing 1 Lux Axial Between |
| | | |
| 2.00 | 4.56 | 9.82 |
| 2.40 | 5.18 | 11.40 |
| 2.50 | 5.31 | 11.80 |
| 2.60 | 5.45 | 12.12 |
| 2.70 | 5.55 | 12.48 |
| 2.80 | 5.66 | 12.80 |
| 2.90 | 5.75 | 13.10 |
| 3.00 | 5.83 | 13.44 |
| 3.10 | 5.90 | 13.80 |
| 3.20 | 5.95 | 14.08 |
| 3.30 | 5.96 | 14.38 |
| 3.40 | 5.95 | 14.66 |
| 3.50 | 5.90 | 14.94 |

| MAINTAINED | 2m Wide Corridor | |
|---------------------|-----------------------------|-----------------------------|
| Mounting Height (m) | Spacing 1 Lux Axial to Wall | Spacing 1 Lux Axial Between |
| | | |
| 2.00 | 4.56 | 9.70 |
| 2.40 | 5.02 | 11.20 |
| 2.50 | 5.15 | 11.56 |
| 2.60 | 5.24 | 11.84 |
| 2.70 | 5.32 | 12.18 |
| 2.80 | 5.40 | 12.50 |
| 2.90 | 5.48 | 12.80 |
| 3.00 | 5.50 | 13.12 |
| 3.10 | 5.50 | 13.40 |
| 3.20 | 5.46 | 13.70 |
| 3.30 | 5.31 | 13.98 |
| 3.40 | 5.32 | 14.20 |
| 3.50 | 2.75 | 14.44 |

EL-DL3
Open Area Luminaire



| NON-MAINTAINED | Open Area to 0.5 Lux | |
|---------------------|----------------------|-----------------|
| Mounting Height (m) | Spacing to Wall | Spacing Between |
| | | |
| 2.00 | 2.85 | 6.19 |
| 2.40 | 3.19 | 7.14 |
| 2.50 | 3.25 | 7.37 |
| 2.60 | 3.30 | 7.57 |
| 2.70 | 3.32 | 7.78 |
| 2.80 | 3.31 | 7.99 |
| 2.90 | 3.31 | 8.20 |
| 3.00 | 3.04 | 8.37 |
| 3.10 | 2.79 | 8.56 |
| 3.20 | 2.55 | 8.73 |

| MAINTAINED | Open Area to 0.5 Lux | |
|---------------------|----------------------|-----------------|
| Mounting Height (m) | Spacing to Wall | Spacing Between |
| | | |
| 2.00 | 2.76 | 6.08 |
| 2.40 | 3.04 | 6.96 |
| 2.50 | 3.08 | 7.20 |
| 2.60 | 3.04 | 7.41 |
| 2.70 | 2.93 | 7.61 |
| 2.80 | 2.70 | 7.78 |
| 2.90 | 2.47 | 7.95 |
| 3.00 | 2.19 | 8.15 |

NFW89/C
High Powered Corridor Luminaire



NFW89/O
High Powered Open Area Luminaire



| NON-MAINTAINED | 2m Wide Corridor | |
|---------------------|-----------------------------|-----------------------------|
| Mounting Height (m) | Spacing 1 Lux Axial to Wall | Spacing 1 Lux Axial Between |
| | | |
| 2.00 | 4.60 | 9.00 |
| 2.20 | 5.00 | 9.60 |
| 2.50 | 5.50 | 10.60 |
| 2.70 | 5.90 | 11.60 |
| 3.00 | 6.60 | 12.60 |
| 3.50 | 7.20 | 14.20 |
| 4.0 | 8.00 | 15.60 |
| 4.50 | 8.90 | 17.00 |
| 5.00 | 9.60 | 19.00 |
| 6.00 | 10.50 | 20.00 |
| 7.00 | 12.00 | 22.00 |

| MAINTAINED | Open Area to 0.5 Lux | |
|---------------------|----------------------|-----------------|
| Mounting Height (m) | Spacing to Wall | Spacing Between |
| | | |
| 2.00 | 3.32 | 6.79 |
| 2.20 | 3.61 | 7.50 |
| 2.50 | 4.03 | 8.49 |
| 2.70 | 4.31 | 9.05 |
| 3.00 | 4.67 | 9.90 |
| 3.50 | 5.37 | 11.31 |
| 4.00 | 6.01 | 12.59 |
| 4.50 | 6.51 | 13.86 |
| 5.00 | 7.00 | 15.13 |
| 6.00 | 7.64 | 17.39 |
| 7.00 | 7.14 | 19.23 |
| 8.00 | 5.44 | 20.51 |