

: F9gMdy Photometric Data

EL-DL2
Corridor Luminaire



NON-MAINTAINED	2m Wide Corridor	
Mounting Height (m)	Spacing 1 Lux Axial to Wall	Spacing 1 Lux Axial Between
2.00	4.56	9.82
2.40	5.18	11.40
2.50	5.31	11.80
2.60	5.45	12.12
2.70	5.55	12.48
2.80	5.66	12.80
2.90	5.75	13.10
3.00	5.83	13.44
3.10	5.90	13.80
3.20	5.95	14.08
3.30	5.96	14.38
3.40	5.95	14.66
3.50	5.90	14.94

MAINTAINED	2m Wide Corridor	
Mounting Height (m)	Spacing 1 Lux Axial to Wall	Spacing 1 Lux Axial Between
2.00	4.56	9.70
2.40	5.02	11.20
2.50	5.15	11.56
2.60	5.24	11.84
2.70	5.32	12.18
2.80	5.40	12.50
2.90	5.48	12.80
3.00	5.50	13.12
3.10	5.50	13.40
3.20	5.46	13.70
3.30	5.31	13.98
3.40	5.32	14.20
3.50	2.75	14.44

EL-DL3
Open Area Luminaire



NON-MAINTAINED	Open Area to 0.5 Lux	
Mounting Height (m)	Spacing to Wall	Spacing Between
2.00	2.85	6.19
2.40	3.19	7.14
2.50	3.25	7.37
2.60	3.30	7.57
2.70	3.32	7.78
2.80	3.31	7.99
2.90	3.31	8.20
3.00	3.04	8.37
3.10	2.79	8.56
3.20	2.55	8.73

MAINTAINED	Open Area to 0.5 Lux	
Mounting Height (m)	Spacing to Wall	Spacing Between
2.00	2.76	6.08
2.40	3.04	6.96
2.50	3.08	7.20
2.60	3.04	7.41
2.70	2.93	7.61
2.80	2.70	7.78
2.90	2.47	7.95
3.00	2.19	8.15

NFW89/C
High Powered Corridor Luminaire



NFW89/O
High Powered Open Area Luminaire



NON-MAINTAINED	2m Wide Corridor	
Mounting Height (m)	Spacing 1 Lux Axial to Wall	Spacing 1 Lux Axial Between
2.00	4.60	9.00
2.20	5.00	9.60
2.50	5.50	10.60
2.70	5.90	11.60
3.00	6.60	12.60
3.50	7.20	14.20
4.0	8.00	15.60
4.50	8.90	17.00
5.00	9.60	19.00
6.00	10.50	20.00
7.00	12.00	22.00

MAINTAINED	Open Area to 0.5 Lux	
Mounting Height (m)	Spacing to Wall	Spacing Between
2.00	3.32	6.79
2.20	3.61	7.50
2.50	4.03	8.49
2.70	4.31	9.05
3.00	4.67	9.90
3.50	5.37	11.31
4.00	6.01	12.59
4.50	6.51	13.86
5.00	7.00	15.13
6.00	7.64	17.39
7.00	7.14	19.23
8.00	5.44	20.51